

SWIMMING POOL AND SPA DAILY RECORD LOG

Location:		Building:	
Pool []	Spa []		
Month:	Year:	Volume (gal):	Flow rate (gpm):

Date	Free Chlorine ((ppm)	pH	Temp (F)	Corrective actions taken / chemicals added
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
	Cyanuric Acid MM	(monthly) dat		CYA ppm:

residual (free chlorine) and pH a minimum of once per day. The pool operator shall maintain a written record. (b) If cyanuric acid (stabilizer) is added to the pool, the operator shall measure the cyanuric acid concentration a minimum of once per month and shall maintain a written record.

Free Chlorine concentration range: POOL 1.0 ppm -10.0 ppm without CYA POOL 2.0 ppm -10.0 ppm with CYA

SPA 3.0 ppm -10.0 ppm with CYA

SPA 3.0 ppm -10.0 ppm without CYA

pH:

Concentration range: 7.2 - 7.8

Cyanuric acid: Concentration range 0.0ppm -100.0ppm

Maximum water temperature: 104°F